

## INSTRUMENT CATHODE-RAY TUBE

14 cm diagonal rectangular flat-faced oscilloscope tube with domed post-deflection acceleration mesh, sectioned y-plates, and metal-backed screen with internal graticule.

QUICK REFERENCE DATA			
Final accelerator voltage	$V_{g9(\ell)}$	20	kV
Display area		100 x 80	mm <sup>2</sup>
Deflection coefficient, horizontal vertical	$M_x$	9	V/cm
	$M_y$	3	V/cm

### SCREEN

Metal-backed phosphor

	colour	persistence
D14-240GH/37	green	medium short

Useful screen dimensions > 100 x 80 mm  
 Spot eccentricity in horizontal and vertical directions < 6 mm

### HEATING

Indirect by a.c. or d.c.; parallel supply

Heater voltage  $V_f$  6,3 V  
 Heater current  $I_f$  300 mA

### MECHANICAL DATA

Mounting position: any

The tube should not be supported by the base alone and under no circumstances should the socket be allowed to support the tube.

Dimensions and connections

See also outline drawing

Overall length (socket included) < 385 mm  
 Face dimensions < 120 x 100 mm

**MECHANICAL DATA** ( continued )

<u>Net mass</u>	≈	900	g
<u>Base</u>		14 pin, all glass	
<u>Accessories</u>			
Socket ( supplied with tube )	type	55566	
Side contact connector ( 12 required )	type	55561	
Final accelerator contact connector	note	1)	
Mu-metal shield	note	2)	

**FOCUSING**

electrostatic

**DEFLECTION**

double electrostatic

x-plates

symmetrical

y-plates

symmetrical

Angle between x and y traces

90°

Angle between x-trace and x-axis of  
the internal graticule

0°

See also "Correction coils"

If use is made of the full deflection capabilities of the tube the deflection plates will intercept part of the electron beam; hence a low impedance deflection plate drive is desirable.

**CAPACITANCES**







$x_1$ to all other elements except $x_2$	$C_{x_1(x_2)}$	4,5	pF
$x_2$ to all other elements except $x_1$	$C_{x_2(x_1)}$	4,5	pF
$y_{1.1}$ to all other elements except $y_{2.1}$	$C_{y_{1.1}(y_{2.1})}$	1,3	pF
$y_{2.1}$ to all other elements except $y_{1.1}$	$C_{y_{2.1}(y_{1.1})}$	1,3	pF
$x_1$ to $x_2$	$C_{x_1x_2}$	3	pF
$y_{1.1}$ to $y_{2.1}$	$C_{y_{1.1}y_{2.1}}$	0,7	pF
Control grid to all other elements	$C_{g_1}$	5,5	pF
Cathode to all other elements	$C_k$	4,5	pF

1) The connection to the final accelerator electrode is made by means of an EHT cable attached to the tube.


2) The diameter of the mu-metal shield should be large enough to avoid damage to the side contacts.

**DIMENSIONS AND CONNECTIONS**

Dimensions in mm



line width 0,15 mm  
dot diameter 0,3 mm



- (1) Recommended position of correction coils.
- (2) See page 2.
- (3) Length of cable approx. 460 mm.
- (4) The bulge at the frit seal may increase the indicated maximum dimensions by not more than 2 mm.

## TYPICAL OPERATION

## Conditions

Final accelerator voltage	$V_{g9(\ell)}$	20	kV
Post deflection accelerator mesh electrode voltage	$V_{g8}$	2000	V
Geometry control electrode voltage	$V_{g7}$	$2000 \pm 150$	V 1)
Interplate shield voltage	$V_{g6}$	2000	V 2)
Deflection plate shield voltage	$V_{g5}$	2000	V 3)
Astigmatism control electrode voltage	$V_{g4}$	$2000 \pm 100$	V 4)
Focusing electrode voltage	$V_{g3}$	500 to 800	V
First accelerator voltage	$V_{g2}$	2000	V
Control grid voltage for visual extinction of focused spot	$V_{g1}$	-55 to -110	V
Voltage on outer conductive coating	$V_m$	2000	V

## Performance

Useful scan, horizontal		>	100	mm 5)
	vertical	>	80	mm
Deflection coefficient, horizontal	$M_x$		9	V/cm
			<	9,9
vertical	$M_y$		3	V/cm
			<	3,3
Line width		≈	0,45	mm 6)
Writing speed		>	1,5	cm/ns <sup>7)</sup>
Deviation of linearity of deflection			see note 8	%
Geometry distortion			see note 9	
Grid drive for 10 $\mu$ A screen current		≈	20	V

- 1) The geometry control electrode voltage  $V_{g7}$  should be adjusted within the indicated range (values with respect to the mean x-plate potential).
- 2) The interplate shield voltage should be equal to the mean x-plate potential.
- 3) The deflection plate shield voltage should be equal to the mean y-plate potential. The mean x-plate and y-plate potentials should be equal for optimum performance.
- 4) The astigmatism control electrode voltage should be adjusted for optimum spot shape. For any necessary adjustment its potential will be within the stated range.
- 5) If the tube is operated at a ratio  $V_{g9(\ell)}/V_{g5} < 10$ , the useful scan may be smaller than 100 mm x 80 mm.  
The scanned raster can be shifted and aligned with the internal graticule by means of correction coils fitted around the tube.

## LIMITING VALUES (Absolute maximum rating system)

Final accelerator voltage	$V_{g9(\ell)}$	max. min.	21 kV 15 kV
Post deflection acceleration mesh electrode voltage	$V_{g8}$	max.	2200 V
Geometry control electrode voltage	$V_{g7}$	max.	2400 V
Interplate shield voltage	$V_{g6}$	max.	2200 V
Deflection plate shield voltage	$V_{g5}$	max.	2200 V
Astigmatism control electrode voltage	$V_{g4}$	max. min.	2300 V 1800 V
Focusing electrode voltage	$V_{g3}$	max.	2200 V
First accelerator voltage	$V_{g2}$	max. min.	2200 V 1900 V
Control grid voltage	$-V_{g1}$	max. min.	200 V 0 V
Cathode to heater voltage			
positive	$V_{kf}$	max.	125 V
negative	$-V_{kf}$	max.	125 V
Voltage between astigmatism control electrode and any deflection plate	$V_{g4/x}$ $V_{g4/y}$	max. max.	500 V 500 V
Grid drive, average		max.	30 V
Screen dissipation	$W_{\ell}$	max.	8 mW/cm <sup>2</sup>
Ratio $V_{g9}/V_{g5}$	$V_{g9}/V_{g5}$	max. min.	10 8
Control grid circuit resistance	$R_{g1}$	max.	1 M $\Omega$

6. Measured with the shrinking raster method in the centre of the screen, with corrections adjusted for optimum spot size, at a beam current of 10  $\mu$ A.

7. Writing speed measuring conditions:

Film	Polaroid 410 (10 000 ASA)
Lens	F 1/1,2
Object to image ratio	1/0,5
Modulation	$\Delta V_{g1} = 55$ V

8. The deflection coefficient over each division will not differ more than 5% from that over any other division; all these deflection coefficients being measured per division along the axes.

9. A graticule consisting of concentric rectangles of 95 mm x 75 mm and 93 mm x 73,6 mm is aligned with the electrical x-axis of the tube. With optimum corrections applied, the edges of a raster will fall between these rectangles.

**CORRECTION COILS**

On request a correction coil unit can be made available consisting of:

1. a pair of coils L1 and L2 which enable the angle between the x and y traces at the centre of the screen to be made exactly  $90^{\circ}$  (orthogonality correction).
2. a pair of coils L3 and L4 which enable the scanned area to be shifted up and down (vertical shift).
3. a coil L5 for image rotation which enables the alignment of the x trace with the x lines of the graticule.

**Orthogonality (coils L1 and L2)**

The current required under typical operating conditions with mu-metal shield being used is  $< 8$  mA for complete correction of orthogonality.

The resistance of each coil is  $\approx 160 \Omega$ .

**Shift (coils L3 and L4)**

The current required under typical operating conditions with mu-metal shield being used is  $< 12$  mA for a maximum shift of 5 mm.

The resistance of each coil is  $\approx 160 \Omega$ .

**Image rotation (coil L5)**

The image rotation coil is wound concentrically around the tube neck. Under typical operating conditions 27 ampere-turns are required for the maximum rotation of  $5^{\circ}$ .

The coil has 1560 turns. This means that a current of  $< 18$  mA is required.

The resistance of the coil is  $\approx 185 \Omega$ .